

Sec. 40-123. - Fire protection.

- (a) *Single-family residential developments.* Fire hydrants shall be installed in all single-family residential developments, which are served by the public water supply at locations shown on the preliminary plat as approved by the city engineer. In no case shall the distance between fire hydrants exceed 500 feet.
- (b) *All other developments.* Fire hydrants shall be installed in all other developments, which are served by a public water supply main. Accessibility for fire fighting equipment shall be maintained through all stages of construction. Fire hydrants and water service shall be installed to within 300 feet of all exterior points of buildings. If the units are of wood framing, the fire hydrants shall be installed before framing begins. The location and number of fire hydrants shall be approved by the city engineer.

(Ord. of 7-1-2002, § 713)